

MUNICIPALITY OF MONROEVILLE  
ALLEGHENY COUNTY, PENNSYLVANIA

ORDINANCE NO. 1979

AN ORDINANCE OF THE MUNICIPALITY OF MONROEVILLE  
AMENDING ORDINANCE NO. 1912 AND ORDINANCE NO. 1583 OF  
THE MUNICIPALITY OF MONROEVILLE AMENDING THE 1987 BOCA  
NATIONAL FIRE PREVENTION CODE

BE IT ORDAINED AND ENACTED, by the Council of the  
Municipality of Monroeville as follows:

SECTION 1. AMENDMENT OF THE 1987 BOCA NATIONAL FIRE  
PREVENTION CODE

That the 1987 BOCA National Fire Prevention Code;  
Appendix A; page 189; NfiPA 30; "Liquids, Flammable and  
Combustible - Code for", pp. 190-191; 30-84 be amended  
as follows.

SECTION 2. AMENDMENTS TO APPENDIX A, NATIONAL BOCA FIRE  
PREVENTION CODE, NFIPA NO. 30

1-1.5.1 The authority having jurisdiction requires all  
tanks for the storage of flammable and combustible  
liquids shall be installed underground.

1-1.5.2 The underground storage tanks shall be in  
strict accordance with the requirements of the  
Pennsylvania Department of Environmental Protection  
pertaining to the underground storage of flammable and  
combustible liquids.

SECTION 3. EXCEPTIONS:

a. Limited amounts of Class IIB not exceeding 100  
gallons of combustible liquids may be installed above  
ground inside structure when protected by 2-hour fire  
resistance construction, automatic fire suppression  
systems, and ventilation systems when approved by the  
authority having jurisdiction.

b. The construction of flammable and combustible  
liquids above ground storage rooms are permitted for  
the requirements of the "1987 BOCA National Building  
Code", provisions as adopted by the Municipality of  
Monroeville per Ordinance No. 1582 of 1987.

SECTION 4.            CAPACITY AND REQUIRED FIRE PROTECTION


1-1.5.2 Class IIIB combustible liquids may be stored above ground providing the following provisions are met:

- a.    A capacity of 300 gallons or less of Class IIIB liquids is the maximum amount permitted for above ground storage.
- b.    Above ground combustible liquid storage tanks must be protected with a 2-hour fire resistance enclosure or a automatic fire extinguishing system as approved by the Municipality of Monroeville.

ORDAINED AND ENACTED into law the 9th of April, 1996.

ATTEST:

MUNICIPALITY OF MONROEVILLE

  
\_\_\_\_\_  
Mary Ann Nau  
Municipal Manager

  
\_\_\_\_\_  
Thomas R. Schuergen  
Mayor

ENTERED INTO LEGAL BOOK:    April 19, 1996